

SECRET

MEMORANDUM FOR THE RECORD

20 SEP 1967

SUBJECT: Construction of Commo Receiver Facility, [REDACTED]
[REDACTED] Job No. 35-65C

25X1A

25X1A

1. A meeting was held in the Real Estate and Construction Division, OL (RECD/OL), 19 September, to coordinate answers to questions raised by the field regarding security aspects of construction of the secure area. Individuals attending were:

25X1A

25X1A

25X1A

25X1A

2. It was agreed that the "floating slab floor concept" mentioned in paragraph 1a, Telepouch [REDACTED] was acceptable. Regarding paragraph 1b of this same message, normal concrete block construction using DURA-WALL or similar joint reinforcing every second or third course was acceptable. Similarly, brick veneer over block, or brick cavity wall construction would be equally adequate for the exterior walls of this area. [REDACTED] pointed out that this area definitely was not a "secure area", according to PSD/OS definition, since it did not have vault doors. However the type construction proposed was adequate since the area was manned 24 hours a day.

3. [REDACTED] advised that PSD/OS was working on the preparation of an intelligence community-wide set of standard specifications for vault and secure area construction. [REDACTED] extension 4144, specifically.) He furnished us an advance copy of the proposed basic vault specification which is attached.


25X1A

4. It was agreed that RECD/OL would work with PSD/OS to assist in preparing these specifications and where practical include sketches of typical, approved types of construction. Also it was not necessary for RECD/OL to await final approval of these standards. We could

Excellent!

RECD
C
DC DMK 9/21/67
EX MP 9/21/67
C/Acq
C/DC 20 Sept.
4. CES- ROW 9/20
File

SECRET



UL 7 6233

SECRET

Approved For Release 2000/06/14 : CIA-RDP78-06505A000300100113-8

SUBJECT: Construction of Commo Receiver Facility, [REDACTED]

25X1A

25X1A

[REDACTED] Job No. 35-65C

25X1A

incorporate them in new construction as PSD/OS established firm

[REDACTED]

25X1A

[REDACTED]

AC/CES/D&CB/RECD/OL

Att

Distribution:

Original - OL/RECD Project

1 - OC-E [REDACTED]

1 - OC/S [REDACTED]

1 - OS/PS [REDACTED]

1 - OL/RECD/D&CB/CES Chrono

25X1A

25X1A

OL/RECD/D&CB/CES [REDACTED] ded
(20 September 1967)

*has been
needed
for a
long time
up*

SECRET

25X1A

Approved For Release 2000/06/14 : CIA-RDP78-06505A000300100113-8

Next 2 Page(s) In Document Exempt

Approved For Release 2000/06/14 : CIA-RDP78-06505A000300100113-8